

# OFFICE OF THE CIVIL SURGEON, RUPNAGAR (PUNJAB)

---

No. GH/229

Date: 04.04.2023

## **SAFE DRINKING WATER** **and** **SANITARY CONDITIONS CERTIFICATE**

It is certified that an inspection team headed by District Health Officer from the office of the Civil Surgeon, Department of Health and Family Welfare, Government of Punjab inspected The Renaissance School, Main Road, Bhanopli, Tehsil-Nangal, District-Ropar (Punjab) on 11.01.2016 and found that The Renaissance School has potable/safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Government.



District Health Officer  
O/o Civil Surgeon, Rupnagar

District Health Office  
O/o Civil Surgeon,  
Rupnagar

To

The Principal  
The Renaissance School  
Main Road, Bhanopli, Tehsil – Nangal  
Distt – Ropar (Pb)

Enclosed:/ Test Report

**State Public Health Laboratory Punjab**  
**Kharar, S.A.S. Nagar (Mohali)**

Email: sphlpb@gmail.com

ID: SPHLPB/165

Dated: 31.03.2023

S. No.	Registration No.	District	Block	Name of Place	Sample Receipt Date	Source	Depth	Colour	Taste	Odour	PH	TDS	Turbidity	Total Alkalinity	Total Hardness	Calcium	Magnesium	Chloride
						Acceptable Limit		5 Hazen	Agreeable	Agreeable	6.5 – 8.5	500 mg/l	1 NTU	200 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l
						Permissible Limit		15 Hazen	Agreeable	Agreeable	No Relaxation	2000 mg/l	5 NTU	600 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l
1	SPHLPB/165	Rupnagar	Nurpur Bedi	The Renaissance School, Bhanopli, Tehsil-Nangal, Rupnagar PB	30.03.2023	Tap Water	-	2	Agreeable	Agreeable	7.45	234.0	1.29	161.0	179.0	50.2	15.1	17.0

  
Bacteriologist  
State Public Health Laboratory Punjab  
Kharar, Distt S.A.S. Nagar (Mohali)  
